

# Application for fitness Certificate of School Buildings

[ TO BE FILLED IN BY THE MANAGER ]

1. Name of school : Amrita Vidyalayam,
2. Location with name of Education Dist / Sub - Dist : Pathanamthitta.
3. Whether Fitness certificate has been issued in previous year and if so the No. and date of the last certificate and the authority who issued it : Yes, 29/12/2020, (2020-21)  
Asst. Exe. Engineers.
4. Classification of the building and size (Basis for classification see Annexure - 1)
  - i) Permanent single or multy storeyed : Permanent - (1)  
(1) MF - 68.73x 6.7m x 3.6m  
(2) FF (68.73m + 7.25m) x 6.7m x 3.6m  
(3) SF - (68.73m + 7.25m) x 6.7m x 3.6m.  
(4) TF (68.73m + 7.25m) x 6.7m x 3.6m
  - Permanent II  
(1) Basement  
(201 + 6.5m) x 6.7m x 2.4m
5. Year of construction of different buildings : 2008-14 .
6. Short specification. Score of the specification : not applicable.
7. i) Foundation and Basement ( Rubble in lime Mortar / cement mortar / mud mortar or laterite lime mortar / cement mortar mud mortar) : RCC Footing and Rubble in Cement
- ii) Super structure (Rubber in lime cement mud or brickerate in lime cement for pillars with intermediate walks with sundried bricks) : RCC Coloumn and baickin Cement .
- iii) Doors and windows country wood ( mention species ) : Anyly wood
- iv) Wood work wrought and put up country wood mention species wrought and full or half bamboo for rafters / iron trusses) : Anyly wood
- v) Kind of roof with short specification of materials used R. C. C. / Taded / thatched / A. C. sheets : R C C Roof
- vi) Flooring : Cement, and Concaete  
Cement plastered over / hand brocken / stone concretes building / gravel concretes gravel beded laterite chips or cowdung washed
- vii) Whether regular maintenance attended to or not : yes

30.65.  
30.65) x 6.7m x 3.6  
(3) FF - Same as MF.  
4. SF - " " "  
5. TF " " "  
1996-97 - 2014 .

I Bai Selhu Nedhavan R.

solemnly declare that the above details furnished are correct to the best of my knowledge.

Place : Pathanamthitta.  
Date : 11.08.2021.

(P. T.)

Principal  
AMRITA VIDYALAYAM  
Mallarakadavu, Pathanamthitta - 689645  
Ph: 0468 - 2325166

TO BE FILLED IN BY THE INSPECTING OFFICER ( Municipal ENGINEER )

1. Name of officer : ANITHA KUMARY

2. Period for which the certificate issued : 2021 - 2022

3. Nature defect, if any :

- a) Foundation and basement
- b) Superstructure
- c) Doors and windows
- d) Wood work wrought and put up
- e) Roof
- f) Flooring
- g) Miscellaneous ( cracks )

NIL

4. Any major defect noted which will make the building unsafe if any manner :

NA

5. Whether maintenance work have been properly done :

YES

6. Whether the structure is sound or not for conducting classes :

The structure is sound under normal wind and weather conditions.

- Note: 1. The stability of the structure should be examined with reference to location altitude of wind exposure to flood etc.  
2. Any additional observation if deemed necessary for the certificate.

Certified that the school was inspected by me on 12/8/2021 and found to be fit to conduct classes for the period 2021-2022.

Place : Pathanamthitta  
Date : 12/08/2021



Arshad  
08/09/2021  
ENGINEER  
Assistant Engineer  
LSGD (ENGG WING)  
Pathanamthitta Municipality